



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

10/29/2025

SUBJECT: BRES2408-0007
BUILDING RESIDENTIAL

To: SRP CAMERON LLC

Here are the results of all Inspections located at **443 TED BROWN RD:**

Inspection Type: ADDRESS

Scheduled Date/Time:

Completed Date/Time:

Inspector: GIS Bucket

Result:

Remarks:

Notes:

Inspection Type: MH FOUND/MARRIAGE WALL

Scheduled Date/Time: 8/12/2025

Completed Date/Time: 8/12/2025

Inspector: Ricardo D Honrada

Result: DISAPPROVED

Remarks:

Notes: LOCK BOX 4648

Need house number.

Inspection Type: ENVIR OPERATIONS PERMIT

Scheduled Date/Time: 9/11/2025

Completed Date/Time: 9/11/2025

Inspector: Mark Osborne

Result: APPROVED

Remarks:

Notes:

Inspection Type: MH FOUND/MARRIAGE WALL

Scheduled Date/Time: 10/13/2025

Completed Date/Time: 10/13/2025

Inspector: Ricardo D Honrada

Result: APPROVED

Remarks:

Notes: LOCK BOX 4648

Underground feeder from service main disconnect to sub panel, the depth more than 24 inches.Two grounding rods and GEC verified.Marriage wall interior and exterior connections ok.



Harnett County
420 Mckinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: WATER SERVICE INSPECTION

Scheduled Date/Time: 10/13/2025

Completed Date/Time: 10/13/2025

Inspector: Ricardo D Honrada

Result: APPROVED

Remarks:

Notes:

Inspection Type: SEWER SERVICE INSPECTION

Scheduled Date/Time: 10/13/2025

Completed Date/Time: 10/13/2025

Inspector: Ricardo D Honrada

Result: APPROVED

Remarks:

Notes:

Inspection Type: ZONING

Scheduled Date/Time: 10/28/2025

Completed Date/Time: 10/28/2025 11:15 AM

Inspector: Kyle Holder

Result: APPROVED

Remarks:

Notes: lock box 4610

Inspection Type: FINAL**

Scheduled Date/Time: 10/29/2025

Completed Date/Time: 10/29/2025

Inspector: Ricardo D Honrada

Result: APPROVED

Remarks:

Notes: lock box is 4610