



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

10/21/2024

SUBJECT: BRES2408-0025
BUILDING RESIDENTIAL

To: EDGAR ADAM RILEY

Here are the results of all Inspections located at **168 WILDWOOD WAY:**

Inspection Type: FOOTING
Scheduled Date/Time: 8/23/2024
Completed Date/Time: 8/23/2024
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 10/8/2024
Completed Date/Time: 10/8/2024
Inspector: Ricardo D Honrada
Result: DISAPPROVED
Remarks:
Notes: Missing nails ledgers 6 inches apart. Need lugs bolts on the band and girder to the post. Need blocking on the stringers and lugs bolts.

Inspection Type: FINAL**
Scheduled Date/Time: 10/16/2024
Completed Date/Time: 10/16/2024
Inspector: Ricardo D Honrada
Result: APPROVED
Remarks:
Notes: