

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

November 13th, 2024

Pamela White
112 Restonwood Dr
Sanford, NC 27332

Re: Status of Permit Application-BRES2408-0037

To whom it may concern,

An attempt was made to evaluate your property for issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines, survey irons to be located and demonstrated. Property lines marked/flagged every 50'. (25.00 Fee Incurred)
- 2. House Box needs to be marked/demonstrated. (25.00 Fee Incurred)
- 3. Directions not clear to property (\$25.00 fee incurred)
- 4. Clear Vegetation. Do not disturb the soil.
- 5. Driveway not shown on site plan
- 6. Backhoe Pits Required-
- 7. **Other- Update site plan with DW setback/measurements to property lines. Must place DW as close to the front property line as possible. Make sure the back left corner of the DW is 10' from the right property line as if you were standing on the road. Must move driveway slightly over 10' to the right as if you were standing from the road. May be required to have duke move your power line to front right corner of property to allow room for DW. Well area was changed to front right of property. Application needs to be revised to 2 bedroom at Central Permitting.**

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7525 ext. 2 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

RL/kh
Copy: Central Permitting