

December 19th, 2024

Eric Flowers
2936 Ashe Ave
Dunn, NC 28334

RE: Existing Tank Application #BRES2408-0045

To whom it may concern

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank fully and break seal. (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Need site plan
- 4. Other – Have a septic contractor to locate and demonstrate drain lines start to end. Clear out abundance of vehicles in backyard for EH to test the soil for a repair area.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7525 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

RL/kh
Copy - Central Permitting