



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

10/25/2024

**SUBJECT: BRES2408-0068**  
**BUILDING RESIDENTIAL**

To: Warlick Harrison

Here are the results of all Inspections located at **121 WINDING CREEK DR:**

Inspection Type: FINAL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: FOUNDATION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: OPEN FLOOR  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: ROUGH IN REINSPECT  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FOOTING  
Scheduled Date/Time: 9/26/2024  
Completed Date/Time: 9/26/2024  
Inspector: Deen Taylor  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: ROUGH IN  
Scheduled Date/Time: 10/24/2024  
Completed Date/Time: 10/24/2024  
Inspector: Scott Guy  
Result: DISAPPROVED  
Remarks:  
Notes: Header beams size too small for post span.