



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

12/13/2024

SUBJECT: BRES2409-0012
BUILDING RESIDENTIAL

To: PEGUERO KARI APRIL

Here are the results of all Inspections located at **203 HOPE ST:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: INSULATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time:
Completed Date/Time:
Inspector: Unassigned
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 12/10/2024
Completed Date/Time: 12/10/2024
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks:
Notes: Lockbox: 5018



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: Owner Must be present for inspection. Will need correct type drywall around tub. Remove
Scheduled Date/Time: installed drywall to allow for inspection. Insulation installed doesnt meet code. Dryer duct not
Completed Date/Time: installed. Missing fireblocking. Need 3" horizontal to washer box. No tests on plumbing.
Inspector: Washer box circuit must be dedicated.
Result: