



Permit Inspections

Harnett County

Permit Number: BRES2409-0015

Description: 16x66 swmh 3 beds

Applied: 9/9/2024

Approved: 10/7/2025

Site Address: 66 SUE ST

Issued: 10/8/2025

Finalized:

City, State Zip Code: SPRING LAKE, NC 28390

Status: ISSUED

Applicant: Douglas Newcomb

Parent Permit:

Owner: ANDERSON CREEK MHP SPRING LAKE NC LLC

Parent Project:

Contractor: Harris Mobile Home Movers

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			ADDRESS	GIS Bucket		
Notes:						
			FOOTING	James T Hall		
Notes:						
			SEWER CONNECTION	James T Hall		
Notes:						
			WATER CONNECTION	James T Hall		
Notes:						
	10/30/2025	10/30/2025	MFH FINAL**	James T Hall	DISAPPROVED	
Notes:						
Missing outside lights at doors						
	11/3/2025	11/3/2025	MFH FINAL**	James T Hall	FAIL W/ PENALTY	
Notes:						
Previous items not corrected						
	11/5/2025		MFH FINAL**	James T Hall		
Notes:						
20	10/15/2025	10/15/2025	MH FOUND/MARRIAGE WALL	James T Hall	DISAPPROVED	
Notes:						
House lockedNeed expansion tank at water heater						



Permit Inspections

Harnett County

20	10/20/2025	10/20/2025	MH FOUND/MARRIAG E WALL	Ricardo D Honrada	FAIL W/ PENALTY	
Notes: Inspector JTH changed the inspection assignment from JTH to RH House is locked.						
20	10/22/2025	10/22/2025	MH FOUND/MARRIAG E WALL	James T Hall	APPROVED	
Notes: Back door is unlocked						
30	10/27/2025	10/27/2025 1:45 PM	ZONING	Randy Baker	APPROVED	
Notes: Arrived at 8:10 and door was locked						
40	10/28/2025	10/28/2025	MFH FINAL**	Kory S Denny	DISAPPROVED	