



Permit Inspections

Harnett County

Permit Number: BRES2409-0016

Description: 16x66 swmh in mhp 3 beds

Applied: 9/9/2024

Approved: 9/9/2025

Site Address: 97 S PEGGY ST

Issued: 9/9/2025

Finalized: 10/17/2025

City, State Zip Code: SPRING LAKE, NC 28390

Status: FINALED

Applicant: Douglas Newcomb

Parent Permit:

Owner: ANDERSON CREEK MHP SPRING LAKE NC LLC

Parent Project:

Contractor: Harris Mobile Home Movers

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			ADDRESS	GIS Bucket		

Notes:

			ENVIR OPERATIONS PERMIT	EH Bucket		
--	--	--	-------------------------	-----------	--	--

Notes:

			FOOTING	James T Hall		
--	--	--	---------	--------------	--	--

Notes:

			SEWER CONNECTION	James T Hall		
--	--	--	------------------	--------------	--	--

Notes:

			WATER CONNECTION	James T Hall		
--	--	--	------------------	--------------	--	--

Notes:

	10/3/2025	10/3/2025	MH FOUND/MARRIAGE WALL	James T Hall	DISAPPROVED	
--	-----------	-----------	------------------------	--------------	-------------	--

Notes:

Support drain line under house per code every 4 foot
Missing cut off and PRV valve at freshwater connection
Need expansion tank at water heater
Insulate water line with R 6.5 per code

	10/8/2025	10/8/2025	MH FOUND/MARRIAGE WALL	James T Hall	APPROVED	
--	-----------	-----------	------------------------	--------------	----------	--

Notes:



Permit Inspections Harnett County

	10/10/2025	10/10/2025	11:00 AM	ZONING	Kyle Holder	APPROVED	
Notes:							
	10/14/2025	10/14/2025		MFH FINAL**	James T Hall	DISAPPROVED	
Notes:							
Need to cover sewer line with 3" of dirt							
	10/16/2025	10/16/2025		MFH FINAL**	James T Hall	FAIL W/ PENALTY	
Notes:							
Need to cover sewer line with 3%34 of dirtMissing lights at front and back doors							
	10/17/2025	10/17/2025		MFH FINAL**	James T Hall	APPROVED	
Notes:							