



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

3/19/2025

SUBJECT: **BRES2409-0029**
BUILDING RESIDENTIAL

To: MCNEILL ROBBIE LEE

Here are the results of all Inspections located at **4520 ROSS RD:**

Inspection Type: FOOTING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: FOUNDATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks: eTRAKiT Inspection Request
Notes: 3/14/2025 3:47 PM ROBBIE MCNEILL

Contact Name: ROBBIE MCNEILL
Site Address: 4520 ROSS RD
Phone: 9109845828
e-Mail: ROBBIE.WOMBLES@YAHOO.COM

Cancelled because the Electrical Rough In needs to be Approved before Building Final.

Inspection Type: ADDRESS
Scheduled Date/Time: 9/19/2024
Completed Date/Time: 9/20/2024
Inspector: GIS Bucket
Result: APPROVED
Remarks:
Notes: 4520 ROSS RD LILLINGTON 27546.

Inspection Type: MONO SLAB
Scheduled Date/Time: 10/29/2024
Completed Date/Time: 10/29/2024
Inspector: James T Hall
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 10/28/2024 1:00 PM Robbie McNeill

Contact Name: Robbie McNeill
Site Address: 4520 ROSS RD
Phone: 9107510768
e-Mail: mbaconcrete24@gmail.com

Inspector JBK changed the inspection assignment from JBK to JTH



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ROUGH IN
Scheduled Date/Time: 12/17/2024
Completed Date/Time: 12/17/2024
Inspector: Daniel L Floyd
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 12/16/2024 9:58 AM ROBBIE MCNEILL

Contact Name: ROBBIE MCNEILL
Site Address: 4520 ROSS RD
Phone: 9109845828
e-Mail: ROBBIE.WOMBLES@YAHOO.COM

Need siding and roof done also need electrical installed Add a king stud each side of the garage door header

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time: 1/23/2025
Completed Date/Time: 1/23/2025
Inspector: Ricardo D Honrada
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 1/21/2025 3:32 PM ROBBIE MCNEILL

Contact Name: ROBBIE MCNEILL
Site Address: 4520 ROSS RD
Phone: 9109845828
e-Mail: ROBBIE.WOMBLES@YAHOO.COM

Need bonded all metal outlet boxes installed outside.Ok to insulate.

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time: 1/27/2025
Completed Date/Time: 1/27/2025
Inspector: John B Kokoszka
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 1/24/2025 8:59 AM ROBBIE MCNEILL

Contact Name: ROBBIE MCNEILL
Site Address: 4520 ROSS RD
Phone: 9109845828
e-Mail: ROBBIE.WOMBLES@YAHOO.COM