



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

3/19/2025

SUBJECT: **BRES2409-0029**  
**BUILDING RESIDENTIAL**

To: MCNEILL ROBBIE LEE

Here are the results of all Inspections located at **4520 ROSS RD:**

Inspection Type: FOOTING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:

Inspection Type: FOUNDATION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:

Inspection Type: SLAB  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: FINAL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks: eTRAKiT Inspection Request  
Notes: 3/14/2025 3:47 PM ROBBIE MCNEILL

Contact Name: ROBBIE MCNEILL  
Site Address: 4520 ROSS RD  
Phone: 9109845828  
e-Mail: ROBBIE.WOMBLES@YAHOO.COM

Cancelled because the Electrical Rough In needs to be Approved before Building Final.

Inspection Type: ADDRESS  
Scheduled Date/Time: 9/19/2024  
Completed Date/Time: 9/20/2024  
Inspector: GIS Bucket  
Result: APPROVED  
Remarks:  
Notes: 4520 ROSS RD LILLINGTON 27546.

Inspection Type: MONO SLAB  
Scheduled Date/Time: 10/29/2024  
Completed Date/Time: 10/29/2024  
Inspector: James T Hall  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 10/28/2024 1:00 PM Robbie McNeill

Contact Name: Robbie McNeill  
Site Address: 4520 ROSS RD  
Phone: 9107510768  
e-Mail: mbaconcrete24@gmail.com

Inspector JBK changed the inspection assignment from JBK to JTH



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: ROUGH IN  
Scheduled Date/Time: 12/17/2024  
Completed Date/Time: 12/17/2024  
Inspector: Daniel L Floyd  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 12/16/2024 9:58 AM ROBBIE MCNEILL

Contact Name: ROBBIE MCNEILL  
Site Address: 4520 ROSS RD  
Phone: 9109845828  
e-Mail: ROBBIE.WOMBLES@YAHOO.COM

Need siding and roof done also need electrical installed Add a king stud each side of the garage door header

Inspection Type: ROUGH IN REINSPECT  
Scheduled Date/Time: 1/23/2025  
Completed Date/Time: 1/23/2025  
Inspector: Ricardo D Honrada  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 1/21/2025 3:32 PM ROBBIE MCNEILL

Contact Name: ROBBIE MCNEILL  
Site Address: 4520 ROSS RD  
Phone: 9109845828  
e-Mail: ROBBIE.WOMBLES@YAHOO.COM

Need bonded all metal outlet boxes installed outside.Ok to insulate.

Inspection Type: ROUGH IN REINSPECT  
Scheduled Date/Time: 1/27/2025  
Completed Date/Time: 1/27/2025  
Inspector: John B Kokoszka  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 1/24/2025 8:59 AM ROBBIE MCNEILL

Contact Name: ROBBIE MCNEILL  
Site Address: 4520 ROSS RD  
Phone: 9109845828  
e-Mail: ROBBIE.WOMBLES@YAHOO.COM