

# OPERATIONS PERMIT

Name: (owner) Res Properties  New Installation  Septic Tank  
 Property Location: SR# NC27  Repairs  Nitrification Line  
 Subdivision Longleaf Acres Lot # 441  
 TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Contractor: J. Faircloth Registration # \_\_\_\_\_  
 Basement with Plumbing:  Garage:  SYSTEM installed during wet soil conditions  
 Water Supply:  Well  Public  Community  
 Distance From Well: 50 ft.


Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_  
 Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
 Subsurface Drainage Field No. of ditches 2 exact length of each ditch 75 ft. width of ditches 3 ft. depth of ditches 18 in.  
 French Drain: \_\_\_\_\_ Linear feet

Date: 03-22-01

PERMIT NO. 17578

Inspected by: Joe Waters  
Environmental Health Specialist



OF-5-1347

HARNETT COUNTY HEALTH DEPARTMENT

No 17578

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Red Properties  New Installation  Septic Tank  
Property Location: SR# 27  Repairs  Nitrification Line

Subdivision Longleaf Acres Phs 2 Lot # 44

Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 3 Lot Size: \_\_\_\_\_

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 75 ft. width of ditches 3 ft. depth of ditches 18 in. MAX


French Drain Required: \_\_\_\_\_ Linear feet

Date: 3/13/2001

This permit is subject to revocation if site plans or intended use change.

Signed: Diana McSwain R.S.  
Environmental Health Specialist

- \* Maintain all setbacks
- \* Run ditches on contour & NO DEEPER than 18 inches
- \* House placement has moved from original site plan as drawn on permit





H/ HARNETT COUNTY HEALTH DEPARTMENT  
AUTORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 17578. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent \_\_\_\_\_

Name: Res Properties Telephone # 822-4540

Address: P.O. Box 9321 Fayetteville N.C. 28311

Property Location: SR # 27 Road Name \_\_\_\_\_

New Installation  Repair  Septic Tank  Nitrification Lines

Subdivision Longleaf Acres Phs. 2 Lot # 44

Number of Bedrooms Proposed: 3 Lot size: .50Ac

Basement  With Plumbing  Without Plumbing

Water Supply: Well  Public  Minimum Well Setback: 50 ft.

Type of System: Conventional  Other

Tank Volume: Septic Tank 1000 gallons Pump Chamber \_\_\_\_\_ gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 2 Length of lines 75 ft.

Width of ditches 3 ft. Depth of ditches 18 inches MAX

French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: Roger McJannet P.S. Date: 3/13/2001