



Permit Inspections

Harnett County

Permit Number: **BRES2409-0055**

Description: **16.10 x 39.10 custom inground pool and spa combo**

Applied: **9/23/2024**

Approved: **9/24/2024**

Site Address: **248 TUTOR RD**

Issued: **9/24/2024**

Finalized: **5/23/2025**

City, State Zip Code: **FUQUAY-VARINA, NC 27526**

Status: **FINALED**

Applicant: **Master Pools**

Parent Permit:

Owner: **HIJEK KATHY**

Parent Project:

Contractor: **Master Pools**

Details:

Since pool was shown on house permit, and is going in that spot, I did not send an onsite owner affidavit for customer to complete.
Sent residential land use to complete.

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	2/3/2025	2/3/2025	ELECTRICAL UNDERGROUND	Justin Ryan McLeod	APPROVED	
Notes: Observed at first bonding inspection						
	5/23/2025	5/23/2025	BONDING	Justin Ryan McLeod	APPROVED	
Notes: Approved w/ Exception: Need to see waterbond at pump at final or before.						
30	12/2/2024	12/2/2024	BONDING	Justin Ryan McLeod	APPROVED W/EXC	
Notes: This inspection for the 4 point rebar, bonding of pool wall, bonding wire from pool to equipment pad, conduits for lights. Pool deck bonding will be done at later time. Will need to see pool deck bonding and water bond at pump later						
30	2/3/2025	2/3/2025	BONDING	Justin Ryan McLeod	APPROVED W/EXC	
Notes: They will have another bonding. Need to see waterbond at pump at final or before.						
40	5/8/2025	5/8/2025 10:30 AM	ZONING	Kyle Holder	APPROVED	
Notes:						
50	5/9/2025	5/9/2025	FINAL**	Justin Ryan McLeod	DISAPPROVED	
Notes: Will need fence for pool Rang doorbell no one answered. If any doors open up into pool area after fence installed they will need alarms in compliance with ul2017						



Permit Inspections

Harnett County

50	5/23/2025	5/23/2025	FINAL**	Justin Ryan McLeod	APPROVED	
----	-----------	-----------	---------	-----------------------	----------	--

Notes: