

We are still working on it.

[Quoted text hidden]

Tom Harte <tom@hartepool.com>
To: "Thomas, Daniel J" <daniel.thomas@ncdoi.gov>

Thank you

Wed, Sep 16, 2020 at 3:11 PM

Sent from my iPhone
[Quoted text hidden]

Thomas, Daniel J <daniel.thomas@ncdoi.gov>
To: Tom Harte <tom@hartepool.com>

Mon, Sep 21, 2020 at 10:25 AM

Tom,

After further review of NEC section 680.26(C) in combination with 680.26(B)(1) and its parts (a) and (b) it appears a swimming pool with a "conductive concrete shell" could be used as a method, for bonding the pool water.

Daniel J. (Danny) Thomas Jr.

State Electrical Inspector

Electrical Code Consultant



N.C. Department of Insurance

[Quoted text hidden]