





Permit Inspections

Harnett County

	11/13/2024	11/13/2024	ROUGH IN	John B Kokoszka	DISAPPROVED	eTRAKiT Inspection Request
Notes: 11/11/2024 8:27 PM Branden Toth Framing Inspection Requested Contact Name: Branden Toth Site Address: 90 VAIL CT Phone: 9843045554 e-Mail: branden@pbdnc.com Need 2 nails each side of joist on ledger Windows missing Exterior beam needs to bear solid on 3 beam						
	1/15/2025	1/15/2025	ROUGH IN REINSPECT	Ricardo D Honrada	APPROVED	eTRAKiT Inspection Request
Notes: 1/13/2025 7:19 PM Branden Toth Windows installed. Ready for framing Contact Name: Branden Toth Site Address: 90 VAIL CT Phone: 9843045554 e-Mail: branden@pbdnc.com						
	2/6/2025	2/6/2025	INSULATION	Ricardo D Honrada	APPROVED	eTRAKiT Inspection Request
Notes: 2/4/2025 7:44 PM Branden Toth Ready for Insulation Inspection. Gate is unlocked and access is granted to back of home addition Contact Name: Branden Toth Site Address: 90 VAIL CT Phone: 9843045554 e-Mail: branden@pbdnc.com Been inspected when doing rough in electrical.						
	6/23/2025	6/23/2025	FINAL**	Ricardo D Honrada	DISAPPROVED	eTRAKiT Inspection Request
Notes: 6/19/2025 4:45 PM Branden Toth Contact Name: Branden Toth Site Address: 90 VAIL CT Phone: 9843045554 e-Mail: branden@pbdnc.com Landing girder needs bolts and nuts, Floor joists landing support needs ledger.						
	6/26/2025	6/26/2025	FINAL**	Ricardo D Honrada	APPROVED	eTRAKiT Inspection Request
Notes: 6/26/2025 10:01 AM Branden Toth Contact Name: Branden Toth Site Address: 90 VAIL CT Phone: 9843045554 e-Mail: branden@pbdnc.com						