

November 1st, 2024

Anthony Miller
8296 Christian Light Rd
Fuquay Varina, NC 27526

RE: Existing Tank Application #BRES2410-0006

To whom it may concern

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank fully and break seal. (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Need site plan
- 4. Other – Tank needs a filter. D-box lid needs to be replaced. Have a septic contractor to locate/demonstrate drain lines from start to end. This will allow us to determine the footage needed for the addition wanted of a 3-bedroom. Existing shed seems to be on top of septic drain lines (will be required to be moved if so).**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7525 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

RL/kh
Copy - Central Permitting