

Kimberly Gibbons

From: Dylan Eure
Sent: Wednesday, November 6, 2024 1:56 PM
To: Kimberly Gibbons
Subject: Re: 0587-81-5159.000

Kimberly,

This should be fine. Properties in the 500 yr flood plain are not required to elevate.

Thanks,

Dylan Eure
Erwin Town Planner
(910) 591-4201
deure@erwin-nc.org

From: Kimberly Gibbons <kgibbons@harnett.org>
Sent: Wednesday, November 6, 2024 1:37 PM
To: Dylan Eure <deure@erwin-nc.org>
Subject: 0587-81-5159.000

I just want to verify this is ok for a DWMH. They obtained a zoning permit from you all. This is in the 500 yr flood plain.

Sincerely,

Kimberly Gibbons
Central Permitting Technician
Development Services



(910) 814-6435 | kgibbons@harnett.org

420 McKinney Parkway (physical) | PO Box 65 (mailing) | Lillington, NC 27546

<https://harnett.org/permits/>

Privacy & Confidentiality Notice

Email correspondence to and from this address may be subject to the North Carolina Public Records Law and shall be disclosed to third parties when required by statutes. (NCGS Ch. 132)