



7/8" T-1-11 SIDING OR OSB ATTACH W/ #8 NAILS @ 6" OC AROUND THE PERIMETER AND 12" AT THE INTERMEDIATE SUPPORTS OR 16 GA 1 3/8" STAPLES @ 3" ON CENTER AROUND THE PERIMETER @ 8" AT THE INTERMEDIATE SUPPORTS. PER TABLE R602.3(1c) OF THE 2018 NC BUILDING CODE




NOTES:
 • WHEN PIER HEIGHT EXCEEDS 32" PIER SIZE MUST BE 16"x16"
 • STRAPS SHALL BE PLACED EVERY 8' ALONG LENGTH OF BUILDING AND AT ALL CORNERS



ROOF LOADING (PSF)		FLOOR LOADING (PSF)	
20	LIVE	125	LIVE
10	DEAD	15	DEAD
30	TOTAL	140	TOTAL

WIND LOAD 150 MPH
 BUILDING SIZES FOR AMISH & A FRAME BARN WIDTH'S ARE 8'-0" - 16'-0" IN 24" INCREMENTS
 BUILDING LENGTHS ARE 8'-0" - 40'-0" IN 24" INCREMENTS



RUNNER SPACING NOTES
 8' BUILDING WIDTH - RUNNERS TO BE OFFSET 32 3/8" FROM CENTERLINE OF BUILDING. TOTAL OF 2 RUNNERS.
 10' BUILDING WIDTH - RUNNERS TO BE OFFSET 32 3/8" FROM CENTERLINE OF BUILDING WITH A RUNNER OFFSET 5 3/8" FROM OUTSIDE EDGE OF BUILDING. TOTAL OF 4 RUNNERS.
 12' & 14' BUILDING WIDTH - RUNNER TO BE PLACED ON CENTERLINE OF BUILDING/RUNNERS TO BE OFFSET 32 3/8" FROM CENTERLINE OF BUILDING WITH A RUNNER OFFSET 5 3/8" FROM OUTSIDE EDGE OF BUILDING. TOTAL OF 5 RUNNERS.
 16' BUILDING WIDTH - TOTAL OF 4 RUNNERS TO BE EVENLY SPACED WITH A 5 3/8" OFFSET FROM OUTSIDE EDGE OF BUILDING.

CMU SPACING FOR 8'-0", 10'-0", 12'-0", 14'-0", 16'-0" WIDTHS		
BUILDING LENGTH	# OF BAYS	BAY DIMENSIONS
8'-0"	2	4'-0"
10'-0"	2	5'-0"
12'-0"	2	6'-0"
14'-0"	2	7'-0"
16'-0"	3	6'-0"
18'-0"	3	6'-0"
20'-0"	3	6'-8"
22'-0"	3	7'-4"
24'-0"	3	6'-0"
26'-0"	4	6'-6"
28'-0"	4	7'-0"
30'-0"	4	7'-6"
32'-0"	6	5'-4"
34'-0"	6	5'-8"
36'-0"	6	6'-0"
38'-0"	6	6'-4"
40'-0"	6	6'-8"

STORAGE BUILDING

FOR 150 MPH WIND AREA

OWNER INFORMATION:
 NAME: OUTBACK BUILDINGS
 ADDRESS: 201 PROSPECT ST.
 PROJECT LOCATION:
 STATE: NC
 COUNTY: DAVIDSON
 TOWNSHIP: LEXINGTON

REVISION NOTE

NO. DATE

DRAWN BY: WK
 CHECKED BY: SK
 DATE: 12-9-19
 PROJECT #: 19-11
 SCALE: NTS

