

December 9th, 2024

Christopher Johnson
75 Friendship Lane
Erwin, NC 28339

RE: Existing Tank Application #BRES2411-0042

To whom it may concern

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank fully and break seal. (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Need site plan
- 4. Other – Need to have septic contractor replace the filter in septic tank. Septic contractor needs to locate and demonstrate drain field start to end (may also be asked to add more footage to drain line if possible due to existing 3 bedroom to a 4 bedroom double wide. May be asked to remove structures in violation of the system such as the shed, pool and deck.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7525 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

RL/kh
Copy - Central Permitting