



Permit Inspections

Harnett County

Permit Number: BRES2412-0010

Description: 16x66 swmh in mhp

Applied: 12/4/2024

Approved: 9/26/2025

Site Address: 46 PAT ST

Issued: 9/29/2025

Finalized:

City, State Zip Code: SPRING LAKE, NC 28390

Status: ISSUED

Applicant: Joey Newcomb

Parent Permit:

Owner: ANDERSON CREEK MHP SPRING LAKE NC LLC

Parent Project:

Contractor: Harris Mobile Home Movers

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			ADDRESS	GIS Bucket		
Notes:						
20			MH FOUND/MARRIAGE WALL	James T Hall		
Notes: Over height letter in attachments						
20	10/3/2025	10/3/2025	MH FOUND/MARRIAGE WALL	James T Hall	DISAPPROVED	
Notes: Support drain line under house per code every 4 foot Missing cut off and PRV valve at freshwater connection Need expansion tank at water heater Need engineer letter for over height, Home Insulate water line with R 6.5 per code House locked						
20	10/8/2025	10/8/2025	MH FOUND/MARRIAGE WALL	James T Hall	FAIL W/ PENALTY	
Notes: STILL Need engineer letter for over height Home						
20	10/21/2025	10/21/2025	MH FOUND/MARRIAGE WALL	James T Hall	FAIL W/ PENALTY	
Notes: Need over height home letter or need to set up home per engineered letter provided in portal						
40	10/23/2025	10/23/2025 12:30 PM	ZONING	Kyle Holder	APPROVED	
Notes:						
50			FINAL**	James T Hall		
Notes:						