



Permit Inspections

Harnett County

Permit Number: BRES2412-0061

Description: 16x66 SWMH 3 beds in Anderson Creek MHP

Applied: 12/23/2024

Approved: 10/13/2025

Site Address: 46 S BRENDA ST

Issued: 10/13/2025

Finaled: 10/27/2025

City, State Zip Code: SPRING LAKE, NC 28390

Status: FINALED

Applicant: Joey Newcomb

Parent Permit:

Owner: ANDERSON CREEK MHP SPRING LAKE NC LLC

Parent Project:

Contractor: Harris Mobile Home Movers

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			ADDRESS	GIS Bucket		
Notes:						
	10/15/2025	10/15/2025	MH FOUND/MARRIAGE WALL	James T Hall	DISAPPROVED	
Notes:						
1, repair all tears under house in belly board 2. No wires under house unless in conduit.3. Need expansion tank at water heater						
	10/20/2025	10/20/2025	MH FOUND/MARRIAGE WALL	Ricardo D Honrada	APPROVED	
Notes:						
Inspector JTH changed the inspection assignment from JTH to RH						
	10/23/2025	10/23/2025 12:45 PM	ZONING	Kyle Holder	APPROVED	
Notes:						
	10/27/2025	10/27/2025	FINAL**	Kory S Denny	APPROVED	
Notes:						