

**WELL CONSTRUCTION RECORD (GW-1)****1. Well Contractor Information:**

Well Contractor Name

NC Well Contractor Certification Number

Company Name

**2. Well Construction Permit #:**

List all applicable well construction permits (i.e. UTC, County, State, Variance, etc.)

**3. Well Use (check well use):****Water Supply Well:**

- ☐ Agricultural ☐ Municipal/Public  
☐ Geothermal (Heating/Cooling Supply) ☒ Residential Water Supply (single)  
☐ Industrial/Commercial ☐ Residential Water Supply (shared)  
☐ Irrigation

**Non-Water Supply Well:**

- ☐ Monitoring ☐ Recovery

**Injection Well:**

- ☐ Aquifer Recharge ☐ Groundwater Remediation  
☐ Aquifer Storage and Recovery ☐ Salinity Barrier  
☐ Aquifer Test ☐ Stormwater Drainage  
☐ Experimental Technology ☐ Subsidence Control  
☐ Geothermal (Closed Loop) ☐ Tracer  
☐ Geothermal (Heating/Cooling Return) ☐ Other (explain under #21 Remarks)

**4. Date Well(s) Completed:** 6/6/25 **Well ID#** \_\_\_\_\_**5a. Well Location:**

Facility/Owner Name

Facility ID# (if applicable)

Physical Address, City, and Zip

County

Parcel Identification No. (PIN)

**5b. Latitude and longitude in degrees/minutes/seconds or decimal degrees:**  
(if well field, one lat/long is sufficient)

35.286070 N -79.156945 W

**6. Is(are) the well(s)** ☒ Permanent or ☐ Temporary**7. Is this a repair to an existing well:** ☐ Yes or ☒ No

If this is a repair, fill out known well construction information and explain the nature of the repair under #21 remarks section or on the back of this form.

**8. For Geoprobe/DPT or Closed-Loop Geothermal Wells having the same construction, only 1 GW-1 is needed. Indicate TOTAL NUMBER of wells drilled:** \_\_\_\_\_**9. Total well depth below land surface:** 390 (ft.)  
For multiple wells list all depths if different (example- 3@200' and 2@100')**10. Static water level below top of casing:** 50 (ft.)  
If water level is above casing, use "+"**11. Borehole diameter:** 10 (in.)**12. Well construction method:** Drilled

(i.e. auger, rotary, cable, direct push, etc.)

**FOR WATER SUPPLY WELLS ONLY:****13a. Yield (gpm)** 8 **Method of test:** Air/lift**13b. Disinfection type:** Chlorinate **Amount:** 8 oz.

For Internal Use Only:

**14. WATER ZONES**

FROM	TO	DESCRIPTION
370 ft.	390 ft.	Quartz, Rock, Granite
ft.	ft.	

**15. OUTER CASING (for multi-cased wells) OR LINER (if applicable)**

FROM	TO	DIAMETER	THICKNESS	MATERIAL
42 ft.	175 ft.	6 in.	Sch 40	Galv.

**16. INNER CASING OR TUBING (geothermal closed-loop)**

FROM	TO	DIAMETER	THICKNESS	MATERIAL
ft.	ft.	in.		
ft.	ft.	in.		

**17. SCREEN**

FROM	TO	DIAMETER	SLOT SIZE	THICKNESS	MATERIAL
ft.	ft.	in.			
ft.	ft.	in.			

**18. GROUT**

FROM	TO	MATERIAL	EMPLACEMENT METHOD & AMOUNT
0 ft.	20 ft.	Quartzite	Pow 8 Bags
ft.	ft.		
ft.	ft.		

**19. SAND/GRAVEL PACK (if applicable)**

FROM	TO	MATERIAL	EMPLACEMENT METHOD
ft.	ft.		
ft.	ft.		

**20. DRILLING LOG (attach additional sheets if necessary)**

FROM	TO	DESCRIPTION (color, hardness, soil/rock type, grain size, etc.)
0 ft.	125 ft.	Sand / Clay
125 ft.	140 ft.	Rock / Granite
140 ft.	175 ft.	Rock
175 ft.	250 ft.	Gray Rock
250 ft.	370 ft.	Gray Rock
370 ft.	390 ft.	Quartz, Rock, Granite
ft.	ft.	

**21. REMARKS****22. Certification:**

Signature of Certified Well Contractor

Date 6/6/25

By signing this form, I hereby certify that the well(s) was (were) constructed in accordance with 15A NCAC 02C .0100 or 15A NCAC 02C .0200 Well Construction Standards and that a copy of this record has been provided to the well owner.

**23. Site diagram or additional well details:**

You may use the back of this page to provide additional well site details or well construction details. You may also attach additional pages if necessary.

**SUBMITTAL INSTRUCTIONS****24a. For All Wells:** Submit this form within 30 days of completion of well construction to the following:Division of Water Resources, Information Processing Unit,  
1617 Mail Service Center, Raleigh, NC 27699-1617**24b. For Injection Wells:** In addition to sending the form to the address in 24a above, also submit one copy of this form within 30 days of completion of well construction to the following:Division of Water Resources, Underground Injection Control Program,  
1636 Mail Service Center, Raleigh, NC 27699-1636**24c. For Water Supply & Injection Wells:** In addition to sending the form to the address(es) above, also submit one copy of this form within 30 days of completion of well construction to the county health department of the county where constructed.