



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

3/4/2025

SUBJECT: BRES2501-0041
BUILDING RESIDENTIAL

To: BAREFOOT BRENDAN W

Here are the results of all Inspections located at **42 IDEAL LN:**

Inspection Type: ADDRESS
Scheduled Date/Time:
Completed Date/Time:
Inspector: GIS Bucket
Result:
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: MH FOUND/MARRIAGE WALL
Scheduled Date/Time: 2/18/2025
Completed Date/Time: 2/18/2025
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: ZONING
Scheduled Date/Time: 2/26/2025
Completed Date/Time: 2/26/2025 12:30 PM
Inspector: Kyle Holder
Result: APPROVED
Remarks:
Notes:





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL**

Scheduled Date/Time: 3/3/2025

Completed Date/Time: 3/3/2025

Inspector: Steven Gazlay

Result: DISAPPROVED

Remarks:

Notes:

lock box is 7643

SPG changed Inspection Date/Time from 02/28/2025 to 03/03/2025

Rodent proof skirting. Need water heater pan, WH drain pan and WH blow off must terminate outside skirting. Seal around piping penetrating the floor. Missing sewer cleanout.