Permit Inspections
Harnett County

Permit Number: BRES2502-0019

Description: **14x60 swmh in mhp 2 beds**

Applied: **2/7/2025**
Approved: **2/18/2025**
Site Address: **18 SURRY CT**

Issued: **2/19/2025**
Finaled:
City, State Zip Code: **ANGIER, NC 27501**

Status: **ISSUED**
Applicant: **Teresa Ann Wood**

Parent Permit:
Owner: **D AND S PROPERTIES**

Parent Project:
Contractor: **STATE MOBILE HOME MOVERS**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			FINAL**	Justin Ryan McLeod		eTRAKiT Inspection Request
Notes:						
	3/10/2025	3/10/2025	ADDRESS	GIS Bucket	APPROVED	eTRAKiT Inspection Request
Notes: 3/6/2025 3:17 PM Michelle Hartley LOCK BOX 1872 Contact Name: Michelle Hartley Site Address: 18 SURRY CT Phone: 9108920108 e-Mail: michelle.hartley@claytonhomes.com 18 SURRY CT ANGIER 27501.						
	3/10/2025	3/10/2025	MH FOUND/MARRIAGE WALL	Daniel L Floyd	APPROVED	eTRAKiT Inspection Request
Notes: 3/6/2025 3:18 PM Michelle Hartley LOCK BOX 1872 Contact Name: Michelle Hartley Site Address: 18 SURRY CT Phone: 9108920108 e-Mail: michelle.hartley@claytonhomes.com						

Permit Inspections
Harnett County

	3/13/2025	3/13/2025	12:00 PM	ZONING	Kyle Holder	APPROVED	eTRAKiT Inspection Request

Notes:

3/12/2025 9:50 AM Michelle Hartley
LOCK BOX 1872
Contact Name: Michelle Hartley
Site Address: 18 SURRY CT
Phone: 9108920108
e-Mail: michelle.hartley@claytonhomes.com

	3/17/2025	3/17/2025	FINAL**	Deen Taylor	DISAPPROVED	eTRAKiT Inspection Request

Notes:

3/14/2025 8:16 AM Michelle Hartley
LOCK BOX 1872
Contact Name: Michelle Hartley
Site Address: 18 SURRY CT
Phone: 9108920108
e-Mail: michelle.hartley@claytonhomes.com

Key and lockbox would not open door. Exterior lights at doors to outside not installed.

	3/19/2025	3/19/2025	FINAL**	Scott Guy	DISAPPROVED	eTRAKiT Inspection Request

Notes:

Grade must fall away from the home in rear and end toward driveway. Back fill cannot be against the underpinning.Reference MFG Home code 3.3.4 proper drainage.