

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

March 25th, 2025

Backyard Storage Solutions
3301 Jones Sausage Rd Suite 127
Garner, NC 27529

RE: Existing Tank Application #BRES2503-0001

To whom it may concern

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover outlet lid on septic tank fully and break seal with a handle for access. (\$25.00 fee incurred).

___ 2. Have system pumped out

___ 3. Replace Sanitary T

X 4. Other – Septic drain lines are 1.5' within the proposed structure and cannot meet the 5' setback required from septic to foundation of storage shed. Recommended to move the 16x20 shed to back left corner and inside fence. (2' off fence)

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7525 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

RL/kh

Copy - Central Permitting