



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

4/9/2025

SUBJECT: **BRES2503-0004**  
**BUILDING RESIDENTIAL**

To: New Generation Contractors LLC

Here are the results of all Inspections located at **1814 JONESBORO RD:**

Inspection Type: FINAL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks: eTRAKiT Inspection Request  
Notes:

Inspection Type: POLE  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: ROUGH IN  
Scheduled Date/Time: 3/18/2025  
Completed Date/Time: 3/18/2025  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks:  
Notes: Minimum roof slope not met(see approved plan). Cannot pond water onto existing roof. Roofing not complete.

Inspection Type: ROUGH IN REINSPECT  
Scheduled Date/Time: 3/21/2025  
Completed Date/Time: 3/21/2025  
Inspector: Scott Guy  
Result: APPROVED  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 3/27/2025  
Completed Date/Time: 3/27/2025  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 3/26/2025 12:20 PM New Generation Contractors LLC

Contact Name: New Generation Contractors LLC  
Site Address: 1814 JONESBORO RD  
Phone: 9103363886  
e-Mail: edgar.newgen@gmail.com

Provide ladder to access roof.

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 3/31/2025  
Completed Date/Time: 3/31/2025  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: Roof not pitched per approved plan.

Inspection Type: POLE  
Scheduled Date/Time: 4/2/2025  
Completed Date/Time: 4/2/2025  
Inspector: Steven Gazlay  
Result: CANCELLED  
Remarks:  
Notes: