



Permit Reviews

Harnett County

Permit Number: BRES2503-0009

Description: 44' x 35' Garage/Storage Building Built w/o permits.

Applied: 3/5/2025

Approved:

Site Address: 1105 W STRICKLAND RD

Issued:

Finalized:

City, State Zip Code: DUNN, NC 28334

Status: RECEIVED

Applicant: DRAIME LUCAS A

Parent Permit:

Owner: DRAIME LUCAS A

Parent Project:

Contractor: DRAIME LUCAS A

Details:

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: AUTO						
3/5/2025	3/5/2025	3/6/2025	CENTRAL PERMITTING INTAKE	CP Bucket	APPROVED	
Notes:						
3/5/2025	3/7/2025	3/10/2025	RESIDENTIAL BUILDING	Brad Sutton	DISAPPROVED	in attachments
Notes:						
Building has been up for a few years; customer only has the rendering in attachments.						
Provide engineered plans for metal building from building supplier. If plans are not available, provide engineers letter on design and installation of building, along with Appendix G letter for foundation						
3/7/2025			RESIDENTIAL BUILDING	Building Bucket		
Notes:						