

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550

fax: 910-893-9429

March 27th, 2025

Rising Sun Pools
5608 Hillsborough St
Raleigh, NC 27606

RE: Existing Tank Application #BRES2503-00033

To whom it may concern

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover outlet lid on septic tank fully and break seal with a handle for access. (\$25.00 fee incurred).

___ 2. Have system pumped out

___ 3. Replace Sanitary T

X 4. Other – Pool location does not meet 15' setback off all septic wastewater. Currently the pool is 6' away from a septic drain line. Applicant can apply for a system relocation, or relocate the pool addition to another spot on the property. (Must be 15' off any part of septic system and repair area.)

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7525 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

RL/kh

Copy - Central Permitting