



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

7/25/2025

SUBJECT: **BRES2503-0061**  
**BUILDING RESIDENTIAL**

To: ARISTIDE THOMAS DWIGHT

Here are the results of all Inspections located at **1008 JOE COLLINS RD:**

Inspection Type: FINAL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Steven Gazlay  
Result:  
Remarks:  
Notes:

Inspection Type: ZONING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Planning Bucket  
Result:  
Remarks:  
Notes:

Inspection Type: ELECTRICAL UNDERGROUND  
Scheduled Date/Time: 5/14/2025  
Completed Date/Time: 5/14/2025  
Inspector: Daniel L Floyd  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: BONDING  
Scheduled Date/Time: 5/14/2025  
Completed Date/Time: 5/14/2025  
Inspector: Daniel L Floyd  
Result: DISAPPROVED  
Remarks:  
Notes: Bonding wire must be bonded to wire mesh grid for concrete



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: BONDING  
Scheduled Date/Time: 6/23/2025  
Completed Date/Time: 6/23/2025  
Inspector: John B Kokoszka  
Result: APPROVED  
Remarks:  
Notes: