

**HARNETT COUNTY ENVIROMENTAL HEALTH**

File/Permit #: BRES2504-0009

CDP #:

IMPROVEMENT PERMIT (IP)☒ New☐ Expansion☐ Repair☐ System Relocation☐ Change of Use

Owner: Robin Long

Applicant: Robin Long

Property Location: 432 Farrington Ln (SR 1108)

PIN/Lot Identifier: 9564-73-1055

Subdivision:

Lot #: Block: Section:

Facility Type: 28'x76' DWMH

Number of bedrooms: 5

Number of Occupants: 10

Other:

Design Daily Flow: 480 GPD

LTAR (Initial): .3

gpd/ft²

LTAR (Repair): .3

gpd/ft²

Wastewater System Type: 50% reduction

(Initial)

Pump Required: ☒ Yes ☐ No ☐ May be required

Usable Depth to Limiting Condition (Initial): 28

Wastewater System Type 50% reduction

(Repair)

Pump Required: ☒ Yes ☐ No ☐ May be required

Usable Depth to Limiting Condition (Repair): 26

Effluent Standard: ☒ DSE ☐ HSE ☐ Other:Type of Water Supply: ☒ Private well ☐ Municipal Supply ☐ Other:

Permit conditions:

Flow reduction from 600GPD to 480GPD is attached to the file online

The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This permit is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.

Authorized Agent's Printed Name: Mark Osborne REHS

Date: 09/10/2025

Authorized Agent's Signature:  REHS

Expiration Date: 09/10/2030

CONSTRUCTION AUTHORIZATION (CA)☒ New☐ Expansion☐ Repair☐ System Relocation☐ Change of Use

Owner: Robin Long

Applicant: Robin Long

Property Location: 432 Farrington Ln (SR 1108)

PIN/Lot Identifier: 9564-73-1055

Subdivision:

Lot #: Block: Section:

Facility Type: 28'x76' DWMH

Number of bedrooms: 5

Number of Occupants: 10

Other:

Design Daily Flow: 480 GPD

LTAR: .3

gpd/ft²Effluent Standard: ☒ DSE ☐ HSE ☐ Other:Type of Water Supply: ☒ Private well ☐ Municipal Supply ☐ Other:**Installation Requirements/Conditions**

Wastewater System Type: 50% reduction

Pump Required: ☒ Yes ☐ No ☐ May be required

Septic Tank Size: 1250 gallons

Total Trench Length: 270 feet

Trench Spacing: 9 feet on center

Pump Tank Size: 1250 gallons

Maximum Trench Depth: 15 inches

Soil Cover: 6 inches

Trench Width: 36 inches

Distribution Method: ☐ Serial☒ D-Box or Parallel☐ Pressure Manifold☐ Other:Artificial Drainage Required: Yes ☐ No ☒ If yes, please specify details:Management Entity Required: ☐ Yes ☒ No Minimum O&M Requirements:

Permit conditions:

Flow reduction from 600GPD to 480GPD is attached to the file online

Will need to bring in 6 inches of group II or group III soil for cover over entire drainfield

The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.

Authorized Agent's Printed Name: Mark Osborne REHS

Date: 09/10/25

Authorized Agent's Signature:  REHS

Expiration Date: 09/10/2030

Owner/Legal Representative Signature:

Date:

***See attached site sketch**

Harnett County Environmental Health

SITE SKETCH

PIN 9564-73-1055

Permit Number BRES2504-0009

Robin Long

Applicant's Name

Mark Osborne REH

Authorized State Agent

Subdivision/Section/Lot Number

09/10/2025

Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = NTS

