



Permit Inspections

Harnett County

Permit Number: BRES2504-0051

Description: SWMH in MHP Anderson creek MHP

Applied: 4/16/2025

Approved: 7/8/2025

Site Address: 141 KELLY CREEK ST

Issued: 7/8/2025

Finalized: 9/10/2025

City, State Zip Code: SPRING LAKE, NC 28390

Status: FINALED

Applicant: Tew Thomas

Parent Permit:

Owner: ANDERSON CREEK MHP SPRING LAKE NC LLC

Parent Project:

Contractor: Harris Mobile Home Movers

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			ADDRESS	GIS Bucket		
Notes:						
			FOOTING	James T Hall		
Notes:						
			SEWER SERVICE	James T Hall		
Notes:						
			WATER SERVICE	James T Hall		
Notes:						
	7/18/2025	7/18/2025	MH FOUND/MARRIAGE WALL	James T Hall	DISAPPROVED	
Notes:						
Remove vegetation from under house and plastic needs to cover 100% under HouseSupport drain line under house every 4 feet per code						
	7/22/2025	7/22/2025	MH FOUND/MARRIAGE WALL	James T Hall	APPROVED	
Notes:						
40	7/23/2025	7/23/2025 12:45 PM	ZONING	Kyle Holder	APPROVED	
Notes:						
50	7/24/2025	7/24/2025	MFH FINAL**	John B Kokoszka	DISAPPROVED	
Notes:						
Both. Lands need to be a smooth transition 3ft away from step.						



Permit Inspections Harnett County

50	7/25/2025	7/25/2025	MFH FINAL**	Daniel L Floyd	DISAPPROVED	
Notes: Rear landing is not smooth within 3ft of steps						
50	9/10/2025	9/10/2025	MFH FINAL**	Ricardo D Honrada	APPROVED	
Notes: Inspector JTH changed the inspection assignment from JTH to RH						