

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

May 7th, 2025

Giovanni & Bonita Richie
1446 Neighbors Rd
Dunn, NC 28334

RE: Existing Tank Application #BRES2504-0057

To whom it may concern

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

X **1. Uncover outlet lid on septic tank fully and break seal with a handle for access. (\$25.00 fee incurred).**

 2. Have system pumped out

 3. Replace Sanitary T

X **4. Other – Need to speak to applicant (called 3 times). Need surveyor to uncover and demonstrate the survey property corner irons, and flag property lines every 50'. Need septic contractor to locate and demonstrate septic drain lines.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7525 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

RL/kh

Copy - Central Permitting