



Permit Inspections

Harnett County

Permit Number: **BRES2504-0070**

Description: **26x56 DWMH 4 BED**

Applied: **4/24/2025**

Approved: **6/23/2025**

Site Address: **50 GEOFFREY CIR**

Issued: **6/23/2025**

Finalized:

City, State Zip Code: **BROADWAY, NC 27505**

Status: **ISSUED**

Applicant: **JIMENEZ FELICIANO SALVADOR**

Parent Permit:

Owner: **JIMENEZ FELICIANO SALVADOR**

Parent Project:

Contractor: **CHOO'S MOBILE HOME TRANSIT**

Details:

SEE BOA2503-0003 and notes.

Approved to put double wide and needs BOA money refunded per Emma.

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			ADDRESS	GIS Bucket		
Notes:						
			FOOTING	Steven Gazlay		
Notes:						
			SEWER SERVICE	Steven Gazlay		
Notes:						
			WATER SERVICE	Steven Gazlay		
Notes:						
			ZONING	Planning Bucket		
Notes:						
	7/8/2025	7/8/2025	MH FOUND/MARRIAG E WALL	John B Kokoszka	DISAPPROVED	
Notes:						
Not ready non of the underneath and cross connection completed no water test						
Not ready non of the underneath and cross connection completed no water test						
	9/9/2025	9/9/2025	MH FOUND/MARRIAG E WALL	John B Kokoszka	DISAPPROVED	
Notes:						
Gasket is not correct left side opening No fasteners on the interior marriage line floor gasket right side bedroom, not correctUnderneath the house, marriage line supposed to be 20 inches on Center staggered per documents There's a gasket underneath the house Waterline connection for both halves not complete						



Permit Inspections

Harnett County

	10/2/2025	10/2/2025	MH FOUND/MARRIAG E WALL	John B Kokoszka	APPROVED	
Notes:						
40	8/6/2025	8/6/2025	ENVIR OPERATIONS PERMIT	James Manhart	APPROVED	
Notes:						
50			MFH FINAL**	Steven Gazlay		
Notes:						