

Owner/Legal Representative Signature: \_

## HARNETT COUNTY ENVIROMENTAL HEALTH

File/Permit #: BRES2505-0001

IMPROVEMENT PERMIT (IP) CDP #:
☐ New ☐ Expansion ☐ Repair ☐ System Relocation ☐ Change of Use
Owner: CARTER STEPHEN TROY LEMOND Applicant: CARTER STEPHEN TROY LEMOND
Property Location: 125 RAYMOND AVERY RD ERWIN, NC 28339 PIN/Lot Identifier: 0598-41-1367.000
Subdivision:
Facility Type: DW 32' x 68' Number of bedrooms: 3 Number of Occupants: 6 Other:
Design Daily Flow: 360 GPD LTAR (Initial): .375 gpd/ft² LTAR (Repair): .45 gpd/ft²
Wastewater System Type: 25% Reduction System/ with 1 Existing Conventional Line (Initial)
Pump Required: Yes No May be required Usable Depth to Limiting Condition (Initial): 48"
Wastewater System Type 25% Reduction System (Repair)
Pump Required: Yes No May be required Usable Depth to Limiting Condition (Repair): 48"
Effluent Standard: DSE HSE Other: Type of Water Supply: Private well Municipal Supply Other:
Permit conditions: No Foundation or Gutter Drains to be Directed Towards Septic System. No Cutting or Grading of Soil in Septic or Septic Repair Area.
The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This permit is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.
Authorized Agent's Printed Name: Ren Levocz  Authorized Agent's Signature: Date: 07/02/2025  Expiration Date: 07/02/2030
Authorized Agent's Signature:
CONSTRUCTION AUTHORIZATION (CA)    New
Effluent Standard: DSE HSE Other: Type of Water Supply: Private well Municipal Supply Other:
Installation Requirements/Conditions
Wastewater System Type: 25% Reduction System  Pump Required: Yes No May be required
Septic Tank Size: 1,000 gallons Total Trench Length: 166' feet Trench Spacing: 9' feet on center
Pump Tank Size: gallons
Trench Width: 36" inches Distribution Method: Serial D-Box or Parallel Pressure Manifold Other: Add 2-83' Lines
Artificial Drainage Required: Yes No III If yes, please specify details:
Management Entity Required: Yes No Minimum O&M Requirements:
Permit conditions: Change Septic Tank Placement to allow Fall, while adding 2 - 83' Lines to the existing 75' Conventional Line No Foundation or Gutter Drains to be Directed Towards Septic System. No Cutting or Grading of Soil in Septic or Septic Repair Area.
The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. <u>This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes.</u> The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.  Authorized Agent's Printed Name:    O7/02/25   Date:
Authorized Agent's Signature: Authorized Agent's Signature: LEHS Expiration Date: 07/02/2030

\*See attached site sketch

Date: \_\_

## SITE SKETCH

<sub>PIN</sub> 0598-41-1367.000

Permit Number BRES2505-0001

## CARTER STEPHEN TROY LEMOND

Applicant's Name Ren Levocz Subdivision/Section/Lot Number

Date

Authorized State Agent

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = NTS

