

Harnett County Department of Public Health

PERMIT # Bres 2505-0001

Operation Permit

☒ New Installation ☒ Septic Tank ☒ Nitrification Line ☐ Repair ☒ Expansion

PROPERTY LOCATION: 125 Raymond Avery Rd, Erwin

Name: (owner) Carter Stephen Troy

SUBDIVISION _____

LOT # _____

System Installer: Hendren's Backhoe Service

Basement with plumbing: ☐ Garage ☐ Number of Bedrooms 3


Type of Water Supply: ☐ Community ☒ Public ☐ Well Distance from well _____ feet

System Type: Accepted/conventional Type III (b) chambers Types V and VI Systems expire in 5 years.

(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



PERMIT CONDITIONS:

I. Performance: System shall perform in accordance with Rule .1961.

II. Monitoring: As required by Rule .1961.

III. Maintenance: As required by Rule .1961. Other: _____

Subsurface system operator required? Yes ☐ No ☐

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

IV. Operation: _____

V. Other: _____

☐ D-Box ☐ Pump ☐ Alarm ☐ H2O Line ☐ PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: ☒ Conventional ☒ Other Type III chambers Septic Tank: 1,000 gallons Pump Tank: _____ gallons

Subsurface No. of exact length 68' 75' conventional width of depth of
Drainage Field ditches 3 of each ditch 86\"/>

French Drain Required: _____ Linear feet 86' chambers

Authorized State Agent REHS

Date 8-26-25