

Harnett County Environmental Health**EXISTING SYSTEM APPROVAL**☒ Existing System Approval☒ Site modification (e.g., storage shed) or footprint addition with no DDF or wastewater strength increase☐ Reconnection when the proposed facility is in the same footprint as existing/previous facility☐ Construction Authorization/Notice of Intent to Construct*[issued for reconnection when the proposed facility is not in the same footprint as existing/previous facility pursuant to Session Law 2023-77, Section 5.(c)]**[certified inspectors are not authorized to approve reconnections outside of footprint pursuant to Session Law 2023-77, Section 5.(c)]*

Applicant: BAUTISTA JUAN CARLOS MORALES

Mailing Address: 981 CARSON GREGORY RD ANGIER, NC 27501

City: ANGIER

State: NC Zip: 27501

Phone #: 919-525-4153

Email: morales90.jom@gmail.com

Owner: Same as Applicant

Mailing Address:

City:

State: Zip:

Phone #:

Email:

PIN/Lot Identifier: 0691-64-1385.000 TR#1

Property Location/Address: 981 CARSON GREGORY RD ANGIER, NC 27501

Facility Type: ☒ House/Modular ☐ Mobile/Manufactured Home ☐ Business ☐ Other:

Operation Permit/ATO #: SFD 21 01-0022 Design Daily Flow: 480 GPD

Number of Bedrooms: 4 Max # Occupants: 8 Other:

Wastewater Strength: ☒ Domestic ☐ High Strength ☐ Industrial Process WastewaterWater Supply: ☐ Private well ☐ Public well ☐ Shared well ☒ Municipal Supply ☐ Spring ☐ Other:

Proposed Property Improvement: 12 x 12 Pool House and Pool Equipment, 1 Bath and Shower.

100' x 99' Shop Steel Frame with Future one Bath.

All the following must be checked for approval:

☒ No current or past uncorrected malfunction of the system as described in 15A NCAC 18E .1303(a)(2)☒ DDF and wastewater strength for the proposed facility or site modification do not exceed that of the existing system☒ Proposed facility or site modification meets the setbacks in Section .0600 of 15A NCAC 18E

Approval Conditions: No Driving on Septic Lines When Installing New Additions.

Hook Pool House plumbing into Septic Tank.

Inspector's Printed Name: Ren Levocz

Inspector Certification #: 3345

Inspector's Signature: 

Date: 5-28-25

The existing system approval expires one year after the date of issuance.***See attached site sketch***


EXISTING SYSTEM APPROVAL SITE SKETCH

Operation Permit/ATO #: SFD2101-0022

PIN/Lot Identifier: 0691-64-1385.000 TR#1

Owner: Juan Morales

Property Location/Address: 981 CARSON GREGORY RD ANGIER, NC 27501



*Include the existing and proposed structures and applicable setbacks.