

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

ph: 910-893-7550  
fax: 910-893-9429

May 22nd, 2025

Tony Tyler  
2449 Bethel Baptist Rd  
Spring Lake, NC 28390

**RE: Existing Tank Application #BRES2505-0029**

To whom it may concern

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

☐ 1. Uncover outlet lid on septic tank fully and break seal with a handle for access. (\$25.00 fee incurred).

☐ 2. Have system pumped out

☒ 3. Replace Sanitary T

☐ 4. Other –

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7525 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne, R.E.H.S.  
Environmental Health Specialist  
Harnett County Department of Public Health

MO/kh  
Copy - Central Permitting