



HARNETT COUNTY ENVIROMENTAL HEALTH

File/Permit #: BRES2505-0030

CDP #: _____

IMPROVEMENT PERMIT (IP)

New Expansion Repair System Relocation Change of Use

Owner: TA Womble Private Equity Management LLC Applicant: TA Womble Private Equity Management LLC

Property Location: 2309 Adcock Rd (SR 1235) PIN/Lot Identifier: 0519-56-3064

Subdivision: TA Womble Private Equity Management LLC Lot #: 2B Block: _____ Section: _____

Facility Type: 27'x57' DWMH Number of bedrooms: 3 Number of Occupants: 6 Other: _____

Design Daily Flow: 360 GPD LTAR (Initial): .4 gpd/ft² LTAR (Repair): .4 gpd/ft²

Wastewater System Type: 25% reduction (Initial)

Pump Required: Yes No May be required Usable Depth to Limiting Condition (Initial): 40

Wastewater System Type: 25% reduction (Repair)

Pump Required: Yes No May be required Usable Depth to Limiting Condition (Repair): 40

Effluent Standard: DSE HSE Other: _____ Type of Water Supply: Private well Municipal Supply Other: _____

Permit conditions:

The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This permit is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.

Authorized Agent's Printed Name: Mark Osborne REHS Date: 06/05/2025

Authorized Agent's Signature: [Signature] Expiration Date: 06/05/2030

CONSTRUCTION AUTHORIZATION (CA)

New Expansion Repair System Relocation Change of Use

Owner: TA Womble Private Equity Management LLC Applicant: TA Womble Private Equity Management LLC

Property Location: 2309 Adcock Rd (SR 1235) PIN/Lot Identifier: 0519-56-3064

Subdivision: TA Womble Private Equity Management LLC Lot #: 2B Block: _____ Section: _____

Facility Type: 27'x57' DWMH Number of bedrooms: 3 Number of Occupants: 6 Other: _____

Design Daily Flow: 360 GPD LTAR: .4 gpd/ft²

Effluent Standard: DSE HSE Other: _____ Type of Water Supply: Private well Municipal Supply Other: _____

Installation Requirements/Conditions

Wastewater System Type: 25% reduction Pump Required: Yes No May be required

Septic Tank Size: 1000 gallons Total Trench Length: 225 feet Trench Spacing: 9 feet on center

Pump Tank Size: 1000 gallons Maximum Trench Depth: 24 inches Soil Cover: 6 inches

Trench Width: 36 inches Distribution Method: Serial D-Box or Parallel Pressure Manifold Other: _____

Artificial Drainage Required: Yes No If yes, please specify details: _____

Management Entity Required: Yes No Minimum O&M Requirements: _____

Permit conditions:

The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.

Authorized Agent's Printed Name: Mark Osborne REHS Date: 06/05/25

Authorized Agent's Signature: [Signature] Expiration Date: 06/05/2030

Owner/Legal Representative Signature: _____ Date: _____

*See attached site sketch

Harnett County Environmental Health

SITE SKETCH

PIN 0519-56-3064

Permit Number BRES2505-0030

TA Womble Private Equity Management LLC

TA Womble Private Equity Management LLC / 2B

Applicant's Name
Mark Osborne REHS

Subdivision/Section/Lot Number
06/05/2025

Authorized State Agent

Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = NTS

