

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550

fax: 910-893-9429

June 5th, 2025

Jonathan Acevedo
728 Kensington Park Rd
Fayetteville, NC 28311

RE: Existing Tank Application #BRES2505-0072

To whom it may concern

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover outlet lid on septic tank fully and break seal with a handle for access. (\$25.00 fee incurred).

___ 2. Have system pumped out

___ 3. Replace Sanitary T

X 4. Other – Septic system is not sized for a 4 bedroom home. You will need to either change the land use to a 3 bedroom home or apply for an expansion of the septic system.

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7525 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

MO/kh

Copy - Central Permitting