



August 21, 2025

Julian Rodriguez
181 Rad Street
Lillington, NC 27546
Email: rodriguezpecas@me.com

Reference: Engineering Services
181 Rad Street
Lillington, NC 27546
TE&D Project No.: 2501-020663

To Whom It May Concern:

As requested, a representative of Tyndall Engineering & Design, PA (TE&D) was on-site to observe the following item(s):

- 1) 18' garage door opening on the left side of the garage in-lieu of the plan specified 9' opening. (All Views facing the garage from the driveway.


The following conclusions and recommendations were noted:

- 1) Based on our observations and analysis, the existing 18' garage door opening supported by a (3) 1-3/4" x 24" LVL header will adequately support the anticipated loading conditions.

We appreciate being able to assist you during this phase of the project. If you need further assistance or require additional information, please do not hesitate to contact us.

Sincerely,
Tyndall Engineering & Design


Sean M. Holmes
SMH | 2501-020663


Prentice Tyndall Jr., P.E.

