

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

ph: 910-893-7550

fax: 910-893-9429

July 16, 2025

Jim Hinson Pools LLC  
Attention: Karen Scheller  
5813 Lease Lane  
Raleigh NC 27617

**RE: Existing Tank Application #BRES2506-0061**

Ms. Scheller:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

\_\_\_\_\_ 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).

\_\_\_\_\_ 2. Have system pumped out

\_\_\_\_\_ 3. Replace Sanitary T

\_\_\_\_\_ 4. **Other – The Location of the current proposed pool is not 15' Away from inground pool. Environmental has flagged the start of the initial septic lines and flagged the repair lines. The pool design/placement must be 15' from septic drain lines/Septic repair lines/d-box/and septic tank.**

**-The addition must be marked/demonstrated onsite. (\$25.00 fee incurred)**

Your application will be put on hold until the selected items above have been addressed.  
When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz, R.E.H.S  
Environmental Health Program Specialist  
Harnett County Department of Public Health

RL/slc

Copy - Central Permitting