

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

September 2nd, 2025

Jim Hinson Pools
5813 Lease Lane
Raleigh, NC 27617

RE: Existing Tank Application #BRES2506-0061

To whom it may concern

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

___ 1. Uncover outlet lid on septic tank fully and break seal with a handle for access. (\$25.00 fee incurred).

___ 2. Have system pumped out

___ 3. Replace Sanitary T

X 4. Other – Pool layout encroached on septic drain field setback. Septic lines are flagged. Update site plan, flip pool horizontally instead of vertically and have clear visible measurement. Must have new pool addition marked/demonstrated onsite.

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7525 to confirm** that the items mentioned have been corrected we will then reschedule your property for evaluation.

Sincerely,



Reynold Levocz, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

RL/kh
Copy - Central Permitting