



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

7/23/2025

SUBJECT: **BRES2507-0005**
BUILDING RESIDENTIAL

To: J & D Contractor Service Inc.

Here are the results of all Inspections located at **47 EAGLE CREST CT:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: OPEN FLOOR
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FOOTING

Scheduled Date/Time: 7/22/2025

Completed Date/Time: 7/22/2025

Inspector: Steven Gazlay

Result: DISAPPROVED

Remarks:

Notes: Footings not deep enough. Bottom of footings must be 12" minimum below grade.