



# Permit Inspections

## Harnett County

**Permit Number: BRES2507-0013**

**Description: 15 x 20 Elevated deck platform at rear of home**

**Applied: 7/8/2025**

**Approved: 7/8/2025**

**Site Address: 315 MOONLIGHT DR**

**Issued: 7/18/2025**

**Finaled: 8/12/2025**

**City, State Zip Code: FUQUAY-VARINA, NC 27526**

**Status: FINALED**

**Applicant: Rowland Skylar**

**Parent Permit:**

**Owner: KHEMRAJ PURSHOTAM**

**Parent Project:**

**Contractor: Ty Hope Homes LLC**

**Details:**

### LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			FOOTING	Justin Ryan McLeod		
Notes:						
	7/24/2025	7/24/2025	ROUGH IN	Daniel L Floyd	APPROVED	
Notes:						
	7/29/2025	7/29/2025	FINAL**	Scott Guy	DISAPPROVED	
Notes:						
Footings never approved. 2/ No answer at front door. 3/ No permission to enter gate on file.						
	7/31/2025	7/31/2025	FINAL**	Daniel L Floyd	DISAPPROVED	
Notes:						
Per customer: existing slab no footing inspection needed						
Permission to enter the gate						
David: 336.708.9447						
Need handrail for stairs and a 3'x3' level landing at the bottom of the stairs						
	8/12/2025	8/12/2025	FINAL**	Daniel L Floyd	APPROVED	
Notes:						