

Michelle F. Myatt

From: Brad Sutton
Sent: Thursday, July 10, 2025 1:09 PM
To: Central Permitting Mailbox
Subject: RE: 301 Oakhaven Dr

No. This is an inground pool, so the “pool deck” will be on grade. Whether its pavers, concrete, or some other substrate it will be on grade, so no extra permit would be required.

Brad

From: Central Permitting Mailbox <centralpermitting@harnett.org>
Sent: Thursday, July 10, 2025 11:59 AM
To: Brad Sutton <bsutton@harnett.org>
Subject: FW: 301 Oakhaven Dr

Would you add a deck to this pool permit? It does not look like a traditional deck; more like a patio made out of a different material.

Sincerely,

Michelle Myatt
Central Permitting Technician
Development Services



(910) 814-6421 | mmyatt@harnett.org

420 McKinney Parkway (physical) | PO Box 65 (mailing) | Lillington, NC 27546

<https://harnett.org/permits/>

Privacy & Confidentiality Notice

Email correspondence to and from this address may be subject to the North Carolina Public Records Law and shall be disclosed to third parties when required by statutes. (NCGS Ch. 132)

From: Seth Clark <sclark@bluehavennc.com>
Sent: Thursday, July 10, 2025 11:45 AM
To: Central Permitting Mailbox <centralpermitting@harnett.org>
Cc: Krista Williams <kwilliams@bluehavensc.com>; Joshua Baughman <jbaughman@bluehavensc.com>
Subject: Re: 301 Oakhaven Dr

Following up with the site plan to include measurements to setbacks and property lines, and noted pool deck. Let me know if there is anything else to add. Thanks for your help!

Seth