

## Lacey L. Carpenter

---

**From:** Central Permitting Mailbox  
**Sent:** Monday, July 28, 2025 10:14 AM  
**To:** Carter Smith  
**Subject:** RE: 422 hillandale Dr plan

I have updated the file to include the latest plans sent. Please allow 3-5 days for review.

Please see the remarks from the Plan Reviewer Below:

Brad Sutton

RESIDENTIAL  
BUILDING

Provide a complete set of construction drawings for addition from footings through roof.

Only a floor plan was submitted.

If enclosing existing patio, provide code complaint footing design for roof support. Roof may not be supported on 4 inch slab

7/15/2025 1:57:30 PM

If the latest drawings/plans do not include these changes, it will be disapproved and the revisions will be required.  
Thank you.

---

**From:** Carter Smith <[csmith@hsrgenco.com](mailto:csmith@hsrgenco.com)>  
**Sent:** Friday, July 25, 2025 11:08 AM  
**To:** Central Permitting Mailbox <[centralpermitting@harnett.org](mailto:centralpermitting@harnett.org)>  
**Subject:** Re: 422 hillandale Dr plan

Here is the marked plan

---

**From:** Central Permitting Mailbox <[centralpermitting@harnett.org](mailto:centralpermitting@harnett.org)>  
**Sent:** Wednesday, July 23, 2025 3:47 PM  
**To:** Carter Smith <[csmith@hsrgenco.com](mailto:csmith@hsrgenco.com)>  
**Subject:** RE: 422 hillandale Dr plan

Please revise the plans provided to exclude the gym addition.

Thank you!

---

**From:** Carter Smith <[csmith@hsrgenco.com](mailto:csmith@hsrgenco.com)>  
**Sent:** Tuesday, July 22, 2025 12:38 PM  
**To:** Central Permitting Mailbox <[centralpermitting@harnett.org](mailto:centralpermitting@harnett.org)>  
**Subject:** Re: 422 hillandale Dr plan

we will not be doing the gym addition

HSR General Contracting  
Carter Smith

Vice President of Construction  
910-751-1785

---

**From:** Carter Smith  
**Sent:** Tuesday, July 22, 2025 12:34:25 PM  
**To:** [centralpermitting@harnett.org](mailto:centralpermitting@harnett.org) <[centralpermitting@harnett.org](mailto:centralpermitting@harnett.org)>  
**Subject:** 422 hillandale Dr plan

HSR General Contracting  
Carter Smith  
Vice President of Construction  
910-751-1785