



Alleigh Harvey <aharvey@hsrgenco.com>

To Central Permitting Mailbox

Reply

Reply All

Forward



Sun 8/10/2025 7:42 PM



Hillandale Post Drawing Revised.pdf
865 KB

Updated Information for Review for 422 Hillandale, BRES2507-0043.

1. There will be no trusses as we will be stick building the addition to the home.
2. I have attached a revised drawing to include the patio beam size. It will be a double 12" LVL.
3. The headers above the triple window on the Left Elevation of the home will be built to NC Residential Building Codes in sections 600 & 800 span charts and will have a double 2x10 header, double king and double jack stud to support window opening.
4. The window and sliding door on the Rear Elevation of the home are non-load bearing and will also be built to the NC Residential Building Codes sections 600 & 800 and will have a header of a double 2x10 with standard king and jack studs to support openings.
5. There is one other beam in the addition at the kitchen which is labeled on the plans previously submitted as a 14" LVL and that will be completed per the plan details.

Alleigh Harvey
President/General Contractor
HSR General Contracting Inc.

010-044-0014