



Harnett County
420 Mckinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

10/31/2025

SUBJECT: BRES2507-0048
BUILDING RESIDENTIAL

To: Window Depot of Raleigh

Here are the results of all Inspections located at **51 OXFORD WOODS DR:**

Inspection Type: FOOTING

Scheduled Date/Time:

Completed Date/Time:

Inspector: Deen Taylor

Result:

Remarks:

Notes:

Inspection Type: OPEN FLOOR

Scheduled Date/Time:

Completed Date/Time:

Inspector: Deen Taylor

Result:

Remarks:

Notes:

Inspection Type: ROUGH IN

Scheduled Date/Time: 9/26/2025

Completed Date/Time: 9/26/2025

Inspector: Brad Sutton

Result: DISAPPROVED

Remarks:

Notes: Anchor bolts missing at wall on door side. Ok to insulate. leave insulation up to see anchor bolts

Inspection Type: ROUGH IN

Scheduled Date/Time: 9/30/2025

Completed Date/Time: 9/30/2025

Inspector: Kory S Denny

Result: DISAPPROVED

Remarks:

Notes: Arrived at 10:30 no answer at door. Called contractor and no answer. Please leave permission in the permit to access property or have someone on site during inspection. Thanks.



Harnett County
420 Mckinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: INSULATION

Scheduled Date/Time: 9/30/2025

Completed Date/Time: 9/30/2025

Inspector: Kory S Denny

Result: CANCELLED

Remarks:

Notes:

Inspection Type: ROUGH IN

Scheduled Date/Time: 10/1/2025

Completed Date/Time: 10/1/2025

Inspector: Deen Taylor

Result: APPROVED

Remarks:

Notes: Inspector has permission to enter

Inspection Type: INSULATION

Scheduled Date/Time: 10/1/2025

Completed Date/Time: 10/1/2025

Inspector: Deen Taylor

Result: DISAPPROVED

Remarks:

Notes: Inspector has permission to enter

Gaps in insulation present throughout walls and ceiling, entire thermal envelope must be completely and securely insulated.

Inspection Type: INSULATION

Scheduled Date/Time: 10/3/2025

Completed Date/Time: 10/3/2025

Inspector: Kory S Denny

Result: APPROVED

Remarks:

Notes:

Inspection Type: FINAL**

Scheduled Date/Time: 10/31/2025

Completed Date/Time: 10/31/2025

Inspector: Steven Gazlay

Result: APPROVED

Remarks:

Notes: