

Howerton Services, PLLC
License # P-1716
3513 Cathedral Bell Road
Raleigh, NC 27614
(919) 270-3460

September 17, 2025

Subject: 2277 Neills Creek Road
Lillington, NC 27546
Plan Revision and Inspection Letter
Harnett County Permit #: ERES-2507-0077

Based on the request of the Contractor, 1 item on the approved plans was modified. My assessment is as follows:

- The approved plans show the proposed Porch Roof bearing on an LVL beam adjacent to the 2nd level wall of the home. This home is a single story dwelling. The Contractor framed the roof structure of the Porch to bear on the LVL at the exterior wall of the home. He framed from the LVL over to the existing roof to create a small overframe section. I inspected the modified roof construction. This modified roof overframe construction is acceptable.

The items noted above meet all the requirements of the 2018 North Carolina Building Code for Residences.



09 17 2025 EDT