


M. A. COLVIN ENGINEERING & CONSULTING ASSOCIATES, PLLC
FIRM LICENSE NO P-2813

Showcase Restoration
125 Drake Street
Fayetteville NC 28301
Attn. Mr. Ellis Wright

September 9th, 2025

Subject Engineer's Certification Letter

Re: 2817 Carolina Way
Sanford NC 28301
On- Site Assessment of Existing Kitchen Hallway Wall
Removal and Placement of header in load bearing wall.



09-09-2025

On September 8th, 2025, I visually inspected the above noted items to be addressed to determine structural adequacy. The removal of the existing kitchen and hallway wall was determined to be acceptable due to the finding that it was not load bearing. The relocation of the refrigerator into a space requiring the placement of a header in a load bearing wall to carry the load transfer of the upper stair landing and wall was also analyzed. The placement of (3) 2x4 jacks beneath each end of the header plus (2) 2x4 king jacks on each side of the 2 x 12 header was found to be structurally adequate for the applied existing load and transfer to the foundation.

In accordance with 21 NCAC 56.1103, I hereby certify this document by seal signature and date as noted herein.

Respectfully,

Myers A. Colvin Sr PE, President

Date 09-09-2025

1300 B Pamalee Drive Fayetteville NC 28303
Ph.(910) 223-0052 Mobile. (910)670-2091