

Harnett County Environmental Health**EXISTING SYSTEM APPROVAL**☒ Existing System Approval☐ Site modification (e.g., storage shed) or footprint addition with no DDF or wastewater strength increase☐ Reconnection when the proposed facility is in the same footprint as existing/previous facility☐ Construction Authorization/Notice of Intent to Construct*[issued for reconnection when the proposed facility is not in the same footprint as existing/previous facility pursuant to Session Law 2023-77, Section 5.(c)]**[certified inspectors are not authorized to approve reconnections outside of footprint pursuant to Session Law 2023-77, Section 5.(c)]*

Applicant: Rita Harris

Mailing Address: 189 Shepard Dr

City: Linden

State: NC

Zip: 28356

Phone #: 910-985-0813

Email:

Owner: Same

Mailing Address:

City:

State:

Zip:

Phone #:

Email:

PIN/Lot Identifier: 0555-32-9609

Property Location/Address: 189 Shepard Dr (SR 3103)

Facility Type: ☒ House/Modular ☐ Mobile/Manufactured Home ☐ Business ☒ Other: Adding a pool

Operation Permit/ATO #: BRES2508-0059 Design Daily Flow: 480 GPD

Number of Bedrooms: 4 Max # Occupants: 8 Other:

Wastewater Strength: ☒ Domestic ☐ High Strength ☐ Industrial Process WastewaterWater Supply: ☐ Private well ☐ Public well ☐ Shared well ☒ Municipal Supply ☐ Spring ☐ Other:

Proposed Property Improvement: adding an inground pool


All the following must be checked for approval:

☒ No current or past uncorrected malfunction of the system as described in 15A NCAC 18E .1303(a)(2)☒ DDF and wastewater strength for the proposed facility or site modification do not exceed that of the existing system☒ Proposed facility or site modification meets the setbacks in Section .0600 of 15A NCAC 18E

Approval Conditions:

Inspector's Printed Name: Mark Osborne REHS

Inspector Certification #: 2613

Inspector's Signature: 

Date: 9-16-25

The existing system approval expires one year after the date of issuance.****See attached site sketch****


EXISTING SYSTEM APPROVAL
SITE SKETCH

Operation Permit/ATO #: BRES2508-0059

PIN/Lot Identifier: 0555-32-9609

Owner: Rita Harris

Property Location/Address: 189 Shepard Dr (SR 3103)



← Shepard Dr →
*Include the existing and proposed structures and applicable setbacks.